

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE C9e		PAGE 1 OF 2 PAGES	
2. AMENDMENT/MODIFICATION NO. 0002		3. EFFECTIVE DATE 01SEP15		4. REQUISITION/PURCHASE REQ. NO. F1SD1200-02		5. PROJECT NO. (If applicable)	
6. ISSUED BY CODE		7. ADMINISTERED BY (If other than Item 6) CODE					
USAF Procurement Branch Contracting Division 100 Kindel Drive, Suite A332 Arnold AFB TN 37389-1332 Buyer/Symbol: Tony Clayborne/PKP Phone: (931) 454-3918				8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)			
				9A. AMENDMENT OF SOLICITATION NO. F40650-01-Q-0021			
				9B. DATED (SEE ITEM 11) 01SEP04			
				10A. MODIFICATION OF CONTRACT/ORDER NO.			
				10B. DATED (SEE ITEM 13)			
CODE		FACILITY CODE					
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS							
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers <input checked="" type="checkbox"/> is extended, <input type="checkbox"/> is not extended.							
Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:							
(a) By completing Items 8 and 15, and returning <u>ONE</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGEMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.							
12. Accounting and Appropriation Data (If required) N/A							
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.							
<input checked="" type="checkbox"/> A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.							
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc). SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).							
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:							
D. OTHER (Specify type of modification and authority)							
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.							
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) The purpose of this Amendment is to incorporate the following changes to the Statement of Work and extend the quote due date as follows:							
A) Attachment 1, Contract Specifications for Installation of Standby Generator dated 12 January 2001, is hereby amended to include the following additions:							
(1) Section 01010, Summary of Work, paragraph 3.1, Schedule, add the following: All electrical outages required for connection of the generator to the existing electrical system shall be scheduled and coordinated with the Government Representative for approval. Outages shall be no longer than 2 hours in duration for any 48 hour period.							
(2) Section 16235, Standby Generator, paragraph 1.1 a), add the following: Designation B, Code G.							
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.							
15A. NAME AND TITLE OF SIGNER (Type or print)				16A. NAME AND TITLE OF SIGNER (Type or print)			
				TONY CLAYBORNE/Contracting Officer			
15B. CONTRACTOR/OFFEROR		15C. DATE SIGNED		16B. UNITED STATES OF AMERICA		16C. DATE SIGNED	
(Signature of person authorized to sign)				BY		(Signature of Contracting Officer)	

- (3) Section 16235, Standby Generator, paragraph 1.1 c), add the following: Designation N, Code N.
- (4) Section 16235, Standby Generator, paragraph 1.1 d), add the following: Designation Y, Code L.
- (5) Section 16235, Standby Generator, paragraph 1.1 f), add the following: Code K.
- (6) Section 16235, Standby Generator, paragraph 1.1 g), add the following: Code J.
- (7) Section 16235, Standby Generator, paragraph 1.1 h), add the following: Designation L, Code K.
- (8) Section 16235, Standby Generator, paragraph 1.1, add the following after the sentence that reads “The supplier of the generator set shall be responsible for verifying the accuracy of this data and insuring the generator is adequately sized to operate the above listed equipment under full load conditions.”:

The following operating conditions of the above listed equipment shall be considered in sizing of the generator:

Item a) 2-15 hp blowers - sufficient generator capacity is required for both blowers to operate. However, both blowers will not be started simultaneously and an adjustable time delay exist on each blower to delay startups with the startup of Item d) 1-25 hp compressor.

Item c) 1-1/3 hp pump – sufficient generator capacity is required for pump to operate. However, the pump will not operate during the startup of any of the other equipment.

Item h) 2-10 hp compressors – sufficient generator capacity is required for both compressors to operate. However, both compressors will not be operated simultancously.

B) The quote due date is hereby extended to 21 September 2001 at 4:00 P.M. (local time).